

NEW HAVEN CITY PLAN COMMISSION ADMINISTRATIVE SITE PLAN REVIEW

1498-04A 630 CHAPEL STREET. Administrative Site Plan Review for modifications to stormwater management plan. (Owner/Applicant/Agent: Frank Caico for Spinnaker Residential LLC.)

Site Plan Team Review Date: August 16, 2016

Submission:

- DATA sheet and cover letter with \$100 fee.
- Revised Engineering (Stormwater) Report dated August 1, 2016.
- Revised Drawing Set. 18 Sheets. Received August 12, 2016.

Both peak runoff rates and volumes have been attenuated via the use of porous pavement and are below pre-development levels; the revised application complies with NHZO Section 60(e)(8).

ACTION:

1. Plans noted above are approved.

Date: 24 August 2016
Confirmed by City Plan Commission



Anne K.E. Hartjen, PLA, ASLA
Senior Project Manager