




NOTE TO CONTRACTORS AND VENDORS:
 CONDUIT AND WIRE SIZE MAY VARY DEPENDING ON PROJECT. IT IS UP TO THE CONTRACTORS OR VENDORS TO SUBMIT SHOP DRAWINGS TO THE CITY ENGINEERING DEPARTMENT FOR APPROVAL TO INSURE CONFORMANCE WITH THESE SPECIFICATIONS.




EXTERIOR ELEVATION

NOTE:
 OVERALL CONCRETE PAD DEPTH = 24". ALLOW 2'-0" IN FRONT AND 6" AT REAR OF PAD.

MASS ELECTRICAL APPARATUS
ELECTRICAL CABINET

NOT TO SCALE



INTERIOR ELEVATION

NOTE:
 *SERVICE SIZE MAY VARY DEPENDING ON LOCATION AND LOAD REQUIRED. TO BE DETERMINED BY CITY OF NEW HAVEN LIGHTING MANAGER.

NOTES:

1. MATERIAL: 0.125 5050-H32 ALUMINUM.
2. NEMA TYPE: 3R RATING.
3. VENTILATION ON ROOF AND DOOR.
4. OPEN BOTTOM
5. STAINLESS STEEL FULL LENGTH PIANO HINGE.
6. SINGLE DOOR DESIGN WITH CAPTIVE DOOR RESTRAINT AND CORBIN LOCK.
7. STAINLESS STEEL PADLOCK HANDLE, 3 POINT LATCHING MECHANISM WITH NYLON ROLLERS AT TOP AND BOTTOM.
8. DOOR FRAME DOUBLE FLANGED ON ALL FOUR SIDES.
9. 3/4" PLYWOOD BACK PANEL TREATED WITH CLEAR POLYURETHANE.
10. CABINET POWDER COATED DARK GREY.
9. U.L. LISTED.